



DETAIL A (PLAN)

NOTES:

1. Refer to Applicability Table for details

FITTINGS DETAIL	
Mark No.	Description
1	Elongated Tapping Band - Tapped to 50mmØ BSPT
2	50mmØ MI 63mmØ Poly End Connector
3	DN63 HDPE PN 12.5
4	100 Sluice Valve
5	100 Hydrant, Tee and Riser
6	End Cap and Thrust Block
7	100mm PVC Service Conduit

APPLICABILITY TABLE							
Council	BSC	CHRC	GRC	IRC	LSC	MRC	RRC
Applicable	Yes	Yes	Yes	Yes	Yes	Yes	Yes
Poly Pipe and Class	PN12.5	PN12.5	PN12.5	PN12.5	PN16	PN12.5	PN12.5

REVISIONS		DATE
E	POLY PIPE CLASS AMENDED FOR LSC	09/2023
D	IRC ADDED	11/2016
C	GRC AND LSC ADDED	09/2014
B	RRC AMENDMENTS	05/2011
A	ORIGINAL ISSUE	01/2010

DISCLAIMER.	
The authors and sponsoring organisations shall have no liability or responsibility to the user or any other person or entity with respect to any liability, loss or damage caused or alleged to be caused, directly or indirectly, by the adoption and use of these Standard Drawings including, but not limited to, any interruption of service, loss of business or anticipatory profits, of consequential damages resulting from the use of these Standard Drawings. Persons must not rely on these Standard Drawings as the equivalent of, or a substitute for, project-specific design and assessment by an appropriately qualified professional.	

Capricorn Municipal Development Guidelines	
Incorporating:	
Banana Shire Council (BSC)	Maranoa Regional Council (MRC)
Central Highlands Regional Council (CHRC)	Rockhampton Regional Council (RRC)
Gladstone Regional Council (GRC)	Isaac Regional Council (IRC)
Livingstone Shire Council (LSC)	

CUL-DE-SAC SCOUR DETAILS	
--------------------------	--

WATER	
STANDARD DRAWING	A3
CMDG-W-081	
REV.	A B C D E