



1. This is regulated work and requires a Plumbing & Drainage Act Permit & Certificate.
2. Concrete S32 in accordance with AS 1379 and AS 3600.
3. Aluminium Sheet 5083-H321, Extruded sections 6061-T6, to AS 2848.
4. All dimensions in millimetres.
5. Backflow Warning signage as per AS/NZS 3500

APPLICABILITY TABLE							
Council	BSC	CHRC	GRC	IRC	LSC	MRC	RRC
<b>Applicable</b>	Yes	Yes	Yes	Yes	Yes	Yes	Yes
<b>Poly Pipe and Class</b>	PN12.5	PN12.5	PN12.5	PN12.5	PN16	PN12.5	PN12

REVISIONS		DATE
F	POLY PIPE CLASS AMENDED FOR LSC	09/2023
E	IRC ADDED	11/2016
D	GRC ADDED	02/2014
C	A,EMDED 50mm BALL VALVE	22/2013
B	RRC AMENDMENTS	05/2011
A	ORIGINAL ISSUUE	01/2010

**DISCLAIMER.**

The authors and sponsoring organisations shall have no liability or responsibility to the user or any other person or entity with respect to any liability, loss or damage caused or alleged to be caused, directly or indirectly, by the adoption and use of these Standard Drawings including, but not limited to, any interruption of service, loss of business or anticipatory profits, of consequential damages resulting from the use of these Standard Drawings. Persons must not rely on these Standard Drawings as the equivalent of, or a substitute for, project-specific design and assessment by an appropriately qualified professional.

Banana Shire Council (BSC) Maranoa Regional Council (MRC)  
Central Highlands Regional Council (CHRC) Rockhampton Regional Council (RRC)  
Gladstone Regional Council (GRC) Isaac Regional Council (IRC)  
Livingstone Shire Council (LSC)

## BACKFLOW PREVENTION DEVICE SLAB AND POLE MOUNTED CUBICLE

WATER						
STANDARD DRAWING					A3	
CMDG-W-030						
REV.	A	B	C	D	E	F