


— 367
— 368
— 369
— 370
— 371
— 372
— 373
— 374
— 375
— 376
— 377
— 378
— 379
— 380
— 381
— 382
— 383
— 384
— 385
— 386
— 387
— 388
— 389
— 390
— 391
— 392
— 393
— 394
— 395
— 396
— 397
— 398
— 399



SAFE-FS K384		
DIP SWITCH	SETTING	MODE FUNCTION
1	OFF	HIGH LEVEL ALARM
2	ON	10 SECOND PUMP & ALARM ACTIVATION DELAY
3	ON	10 SECOND PUMP & ALARM DEACTIVATION DELAY
4	OFF	N/C LEVEL ALARM
5	OFF	N/C FAILSAFE PROBE ALARM
6	N/A	NOT USED
7	ON	PROBE SENSITIVITY – 80k OHM
8	ON	



**GLADSTONE REGIONAL
COUNCIL**

P.O. Box 29, Gladstone Qld. 4680

DRAWING NO.		
GRC-ED-082		
A1 SHEET	REVISION	0